



NOTES:

1. For construction in existing asphalt streets, refer to Detail 12.0 for asphalt patch requirements.
2. For (A), (L) and (T) joints, refer to Detail 11.2.
3. All commercial & multi family driveways shall install approach widening unless otherwise approved by Engineer.
4. Wider driveway than shown may be approved by the Engineer.
5. 6" Thick Concrete Paving is the minimum requirement. Driveways servicing heavy truck traffic may require 8" thick paving.
6. Tooled contraction joints are required to control the location of cracking and to provide definition of sidewalk and driving surfaces. Tooled joints for driveway approaches shall be located as indicated above. Additional longitudinal tooled joints may be required when the driveway width exceeds 15'.
7. Tree grate cannot be used as part of the sidewalk.

DATE: 5/05

CITY & COUNTY OF DENVER

PUBLIC WORKS

STD. DWG NO.

STANDARD COMMERCIAL & MULTI FAMILY DRIVEWAY



6.1