


CITY AND COUNTY OF DENVER		POLICY	DENVER FIRE DEPARTMENT
Subject: MARIJUANA ESTABLISHMENTS OR BUSINESSES			
Reference: 2016 Denver Fire Code (DFC)			
Approved:			
 Manuel Almaguer, Division Chief, Fire Prevention Division			
Number: DFC 105.6	Effective Date: August 1, 2018	Page 1 of 4	

This policy is meant to provide basic information for most common conditions and situations. In any given occupancy, all Fire Code requirements will be enforced, Fire Inspectors will address these during inspections. Questions can be addressed by contacting the Fire Prevention Division at 720-913-3474 or at DFDMARIJUANAENFORCEMENT@DENVERGOV.ORG

I. SCOPE

This policy shall apply to all marijuana establishments or businesses located within the City & County of Denver. These establishments or businesses involve unique operations which create significant life safety and fire hazards. As such, all establishments or businesses engaging in these activities shall be required to obtain all applicable annual operational permits from the Denver Fire Department – Fire Prevention Division.

New and/or existing marijuana related establishments or businesses may require construction permits or a change of occupancy; this may include access control systems, electrical modifications, addition or deletions of walls, modification to mechanical systems (exhaust hood systems), etc. Please see the Denver Fire Department *Guideline for Construction Permitting for Marijuana Establishments / Businesses Located in Commercial Buildings* for further information during the construction permitting process.

II. DEFINITIONS

For the purposes of this policy, all marijuana related terms are defined per the State of Colorado Marijuana Code 1 CCR 212.

III. PERMITS

Upon Approval by Denver Fire Prevention Division personnel, Annual Operational Permit(s) may be obtained from the Denver Fire Department. To obtain permits, submit a completed application to the MARIJUANA ENFORCEMENT GROUP in person at the Denver Fire Department – Fire Prevention Division, 745 West Colfax Avenue – 1st floor or via email to: DFDMARIJUANAENFORCEMENT@DENVERGOV.ORG

Permit hours are 6:30 AM to 9:00 AM, Monday through Friday if staff is available. (Holidays excepted). Once the permit is approved and ready to be issued, you will be notified with an invoice via email and instructions to pay online or in person.

IV. SPECIFIC REQUIREMENTS

1. Exiting & Security

- Required minimum exit access shall be provided.
- Enhanced building security measures shall by no means impede egress for the facilities' occupants or firefighters in the event of an emergency.
- Fire Department Key Access (Knox Box) shall be provided near the main entrance

CITY AND COUNTY OF DENVER	POLICY	DENVER FIRE DEPARTMENT
Subject: MARIJUANA ESTABLISHMENTS OR BUSINESSES		
Reference: 2016 Denver Fire Code (DFC)		
Number: DFC 105.6	Effective Date: August 1, 2018	Page 2 of 4

- to the facility.
- Where electronic access control is in use, a Denver Building Department 3B permit is required for the installation of the access control system. See Denver Building Code Appendix L.
- Locking hardware on doors (interior or exterior) shall be in accordance with Building Code Policy 1008.1.9.
- Clear aisles shall be maintained through grow rooms in accordance with Denver Fire Code Chapter 10.

2. Fire extinguishers

- Portable fire extinguishers shall be provided within the facility, near exits.
- Travel distance to extinguishers shall not exceed seventy-five (75) feet of travel.
- Minimum extinguisher size permitted is 2A10BC. (IFC 906 & 906.1)

3. Graphic Map

- An 8 ½" x 11" map displaying a general floor plan of the facility shall be provided near the main entrance in a clear protective cover for the cultivation facilities or where the floor plan of the building is complex or may be confusing to first responders in the event of an emergency.

4. Interior Finishes / Building Construction

- Hanging plastic films shall not be used to create walls, ceilings, or rooms. Where plastic films are applied to the walls or ceiling as an interior finish material, the installation shall comply with Chapter 8 of the Building Code. A Building Department construction permit maybe required for installation.

5. Premise Identification

- Address numbers shall be posted per Denver Fire Code 505; minimum 6" numbers with minimum 0.75 stroke width on contrasting background

6. Electrical

- Extension cords, power strips, or multi-outlet assemblies etc. are prohibited from being used as permanent wiring.
- All electrical modifications require review and approval; permanent wiring (new circuits etc) require an electrical permit from the Denver Building Department. Electrical panel load schedules (from engineered electrical permit drawings) shall be posted at each panel.
- Emergency generators shall only be operated after obtaining permits from the Denver Building and Fire Departments.

7. Hazardous Materials/Conditions/Processes

CITY AND COUNTY OF DENVER	POLICY	DENVER FIRE DEPARTMENT
Subject: MARIJUANA ESTABLISHMENTS OR BUSINESSES		
Reference: 2016 Denver Fire Code (DFC)		
Number: DFC 105.6	Effective Date: August 1, 2018	Page 3 of 4

- All hazardous materials shall be properly stored, used & labeled.
- Fumigation, Pesticides, Fungicides, Miticides – use, storage & inventory statement shall not be performed without proper permits and advance notification including submittal of a Pesticide inventory statement.
- Pesticides, Fungicides, Herbicides and Fertilizers shall be properly stored and used in strict accordance with manufactures recommendations and product label.
- Extraction processes and CO2 Enrichment shall not be conducted until all rooms, solvents and equipment have been reviewed/approved and permitted by Denver Fire Prevention Division, including an acceptance test.

V. NOTICE

Any and all occupancies discovered operating marijuana establishments or businesses (including but not limited to marijuana infused product operations, marijuana cultivation, testing labs, and marijuana sales occupancies) not in compliance with all requirements of the of the City & County of Denver and the requirements of this policy may result in the issuance of a “Stop Work Order” and a summons being issued to all offending parties.

CITY AND COUNTY OF DENVER	POLICY	DENVER FIRE DEPARTMENT
Subject: MARIJUANA ESTABLISHMENTS OR BUSINESSES		
Reference: 2016 Denver Fire Code (DFC)		
Approved: Manuel Almaguer, Division Chief, Fire Prevention Division		
Number: DFC 105.6	Effective Date: August 1, 2018	Page 4 of 4

MARIJUANA ESTABLISHMENTS OR BUSINESSES PERMIT APPLICATION

Business Name: _____

Site Address: _____

Billing Address: _____

Business Phone: _____

Owner Name: _____

Owner Address: _____

Owner Phone: _____

Owner E-Mail: _____

Type of establishment, business, and processes (**check all that apply**):

- | | |
|--|---|
| <input type="checkbox"/> Retail Marijuana Store | <input type="checkbox"/> Medical Marijuana Center |
| <input type="checkbox"/> Retail Marijuana Cultivation | <input type="checkbox"/> Medical Marijuana Optional Premise Cultivation |
| <input type="checkbox"/> Retail Marijuana Product Manuf. | <input type="checkbox"/> Medical Marijuana Infused Product |
| <input type="checkbox"/> Retail Marijuana Testing Facility | <input type="checkbox"/> Medical Marijuana Testing Facility |
| <input type="checkbox"/> Retail Marijuana Transporter | <input type="checkbox"/> Medical Marijuana Transporter |
| <input type="checkbox"/> Cannabis Consumption Est. | <input type="checkbox"/> Non-licensed Cultivation |

Additional applications required for initial permit:

- | | |
|---|---|
| <input type="checkbox"/> Plant extraction | <input type="checkbox"/> CO2 enrichment System |
| <input type="checkbox"/> Compressed gas storage/use | <input type="checkbox"/> Fumigation / Thermal Insecticide Fogging |
| <input type="checkbox"/> Flammable liquid storage/use | <input type="checkbox"/> LPG storage/use |
| <input type="checkbox"/> Transfilling | <input type="checkbox"/> Pesticide inventory statement |
| <input type="checkbox"/> Barbed Wire | <input type="checkbox"/> Temporary Heating Appliance |

For **RENEWAL ONLY** (no change to current permit information):

I HAVE READ AND UNDERSTAND THE DENVER FIRE DEPARTMENT POLICY REGARDING MARIJUANA ESTABLISHMENTS OR BUSINESSES. I FURTHER UNDERSTAND THAT A SITE INSPECTION WILL BE CONDUCTED BY DENVER FIRE PREVENTION PERSONNEL AND THAT PERMITS MAY BE REVOKED WITHOUT REFUND IF ANY FIRE/BUILDING CODE VIOLATIONS ARE DISCOVERED.

SIGNATURE: _____ DATE: _____

END OF DOCUMENT
