


39th Avenue Greenway Vibration Monitoring

Week of August 13 to August 18, 2018


3834 Gilpin Street



Noise Monitoring:

Date	Leq (dB(A))	Lmax (dB(A))
August 13-14, 2018	62.9	96.7
August 15, 2018	75.1	93.2
August 15, 2018	71.4	92.5
August 16, 2018	52.5	76.7
August 17, 2018	51.4	80.7


3849 Gilpin Street



Noise Monitoring:

Date	Leq (dB(A))	Lmax (dB(A))
August 13, 2018	51.5	78.7
August 14, 2018	51.5	81.5
August 14, 2018	42.0	44.5
August 15, 2018	52.4	77.7
August 16, 2018	73.3	104.9
August 17, 2018	53.2	79.7
August 17, 2018	51.8	61.6


Construction Vibration Monitor Near Box Culvert



On August 13, August 16, and August 17, 2018, the threshold amplitude of ground vibrations generated from the construction activities exceeded the levels set forth in the U.S. Bureau of Mines (USBM) recommendation (RI 8507 1980) that are capable of producing damage to plaster and drywall in residential structures.

Mr. Charlie Bisbee and Mr. Rigo Gonzales with SEMA informed us that on August 15 and August 16, 2018, someone had tripped or accidentally kicked the geophone and sandbag. They also informed us that on August 17, 2018, the employee setting up the monitor accidentally kicked or tripped over the geophone and sandbag after turning it on for the day.

Sheet Piling



On August 16, 2018, the threshold amplitude of ground vibrations generated from the construction activities exceeded the levels set forth in the U.S. Bureau of Mines (USBM) recommendation (RI 8507 1980) that are capable of producing damage to plaster and drywall in residential structures during sheet pile installation.