


39th Avenue Greenway Vibration Monitoring

Week of September 24 to September 29, 2018

Vibration monitoring was performed at 3849 Gilpin Street, near the box culvert installation, near the sheet pile installation, near the work being performed near Coca-Cola, and on Denver Rock Drill property just off of East 40th Avenue. Exceedances occurred at 3849 Gilpin Street, the box culvert installation, the sheet pile installation, and the Denver Rock Drill property.

3849 Gilpin Street (Zone 4)




Noise Monitoring:

Date	Leq (dB(A))	Lmax (dB(A))
September 24, 2018	58.5	84.9
September 24, 2018	64.6	94.6
September 25, 2018	<30	<30
September 25, 2018	<30	<30
September 26, 2018	68.4	87.2
September 27, 2018	60.5	84.7
September 28, 2018	52.8	90.3

On September 24, and September 27, 2018, the threshold amplitude of ground vibrations generated from the construction activities exceeded the levels set forth in the U.S. Bureau of Mines (USBM)


recommendation (RI 8507 1980) as shown on the graph above. These exceedances on September 24 and September 27, 2018 appeared to have occurred right before the monitor was turned off each day.

Construction Vibration Monitor Near Box Culvert (Zone 2)




On September 26, September 28, and September 29, 2018, the threshold amplitude of ground vibrations generated from the construction activities exceeded the levels set forth in the U.S. Bureau of Mines (USBM) recommendation (RI 8507 1980) as shown on the graph above. On September 28, 2018, the exceedances appeared to have occurred right before the monitor was turned off.

Sheet Piling (Zone 3)




On September 24, 2018, the threshold amplitude of ground vibrations generated from the construction activities exceeded the levels set forth in the U.S. Bureau of Mines (USBM) recommendation (RI 8507 1980) as shown on the graph above. On September 24, the exceedances appeared to have occurred right after the monitor was turned on.

Coca-Cola (Zone 7)



Denver Rock Drill (East 40th Avenue)



On September 26, 2018, the threshold amplitude of ground vibrations generated from the construction activities exceeded the levels set forth in the U.S. Bureau of Mines (USBM) recommendation (RI 8507 1980) as shown on the graph above. On September 26, 2018, the exceedances appeared to have occurred right before the monitor was turned off.