

CITY AND COUNTY OF DENVER
DEPARTMENT OF PUBLIC WORKS
Engineering Division

CONTRACT NO. 201845779
PROJECT NAME: 2018 Citywide Bond Concrete Repair

ADDENDUM NO. 1 TO CONTRACT DOCUMENTS

Bidders are hereby instructed that the drawings, specifications, and other contract documents are modified, corrected, supplemented and/or superseded for the above mentioned project as hereinafter described in the following attachments:

Question and Answers


1. *The HBP Patch/Overlay and we looked through the bid docs and did not find a mix design. Do you have one other than "City and County of Denver approved mix".*

No specific mix design is specified. CDOT approved mix designs for patching will be accepted.

2. *In the pre-bid it says the City will do the concrete testing but there is a line item on the bid schedule for material testing. Please confirm who is to pay for testing.*

The line item for testing will be used to pay for the concrete testing required of the Contractor (air, slump, strength), typically once a week unless concrete does not meet specifications or High Early Concrete is used and further testing is required. The City also has a third party tester on call to verify results. This is paid by the City with a separate contract, not the testing line item.

This ADDENDUM shall be attached to, become a part of, and be returned with the Bid Proposal.



Lesley B. Thomas
City Engineer
12.13.18

Date

The undersigned bidder acknowledges receipt of this Addendum. The Proposal submitted herewith is in accordance with the stipulations set forth herein.

Contractor

ADDENDUM NO. 1

DATE: _____