

Code Amendment Proposal Form

For public amendments proposed to the 2021 editions of the International Codes



Instructions: Upload this form and all accompanying documentation. If you are submitting your proposal on a separate sheet, make sure it includes all information requested below.

All proposals must be received by **July 23, 2021**.

CONTACT INFORMATION

Name: Celeste Cizik

Date: 07/23/21

Phone: 720-382-1705

E-mail: ccizik@group14eng.com

Organization or Representing Self: Group14 Engineering

By signing below, I hereby grant and assign to City and County of Denver all rights in copyright I may have in any authorship contributions I make to City and County of Denver in connection with this proposal. I understand that I will have no rights in any City and County of Denver publications that use such contributions in the form submitted by me or another similar form and certify that such contributions are not protected by the copyright of any other person or entity.

Signature: *Celeste Cizik*

AMENDMENT PROPOSAL

Please use a separate form for each proposal.

1) Code(s) associated with this proposal. Please use acronym: 2021 IECC

If you submitted a separate coordination change to another code, please indicate which code: _____

<u>Acronym</u>	<u>Code Name</u>	<u>Acronym</u>	<u>Code Name</u>
DBC-AP	Denver Building Code—Administrative Provisions	IFC	International Fire Code
DBC-xxxx	Denver Building Code—xxxx (code) amendments (e.g., DBC-IBC, DBC-IEBC)	IFGC	International Fuel Gas Code
IBC	International Building Code	IRC	International Residential Code
IEBC	International Existing Building Code	IMC	International Mechanical Code
IECC	International Energy Conservation Code	IPC	International Plumbing Code
		DGC	Denver Green Code

2) Please check here if a separate graphic file is provided:

Graphics may also be embedded within your proposal below.

3) Use this template to submit your proposal or attach a separate file, but please include all items requested below in your proposal. The only formatting needed is **BOLDING**, ~~STRIKEOUT~~ AND UNDERLINING. Please do not provide additional formatting such as tabs, columns, etc., as this will be done by CPD.

Code Sections/Tables/Figures Proposed for Revision:

Section C405.12 Energy Monitoring

Note: If the proposal is for a new section, indicate (new).

Proposals:

C405.12.2 Exception 3 revise as follows:

3. End-use metering shall not be required for an individual tenant space having a floor area not greater than ~~2,500~~ 5,000 square feet where a dedicated source meter complying with Section C405.12.2 is provided.

C405.12.5 Graphical energy report add new text as follows:

A permanent and readily accessible reporting mechanism shall be provided in the building that is accessible by building operation and management personnel. A web-based software platform accessible by building operation and management

